

MAYOR
Barbara Blain-Bellamy

MAYOR PRO TEM
Larry A. White



COUNCIL MEMBERS
Thomas J. "Tom" Anderson II
William M. Goldfinch IV
Shane Hubbard
Ashley Smith
Jean M. Timbes

PUBLIC WORKS DEPARTMENT

**Addendum #1
Magnolia Maple Drainage HUD Project
Bid Package: 7-6-2018**

TO: All Bidders

FROM: City of Conway Public Works
PO Box 1075
Conway, SC 29528
843-248-1730

DATE: June 21, 2018

All bidders submitting proposals for the above referenced project shall note the following changes to the drawings and/or specifications and all such shall become a part of the contract.

This Addendum consists of one (1) addendum sheet.
Items included in this addendum are the following questions and answers

1. The plans spec. on grassing has a seeding schedule sheet 2 of 4. The Specs. #24 states all areas to be grassed with centipede sod. Which are to be used?

Follow the seeding schedule on sheet 2 of 4. Centipede sod is not required as stated on the Specs. #24.

2. Who is responsible for the relocation of the existing power pole at New Curb Inlet #2 or will it be located before construction?

Santee Cooper is aware of power pole relocation. This will be coordinated during the pre-con.

3. Will retainage be withheld for the milling & overlay of Grainger Road during the waiting period of 6-12 months?

No retainage will be withheld for the milling and overlay of Grainger Road.

ACKNOWLEDGEMENT OF THIS ADDENDUM SHALL BE NOTED ON THE OFFICIAL BID FORM AND NOTED IN THE SUBMITTAL PACKAGE.